

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 600

Date: 28/02/25

It is certified that an inspection team headed by Executive Engineer
E.R. Abhishek Reddy (Name of Officers
with designation) from PHED Division Gaya (Name of
Department/Office) inspected the Gyan Taru Public School Educa
tional Trust Mastalipur Manpur Gaya (Name & Address of
the School) on 27.01.25 and found that the Gyan Taru Public School
Educational Trust Mastalipur Manpur (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year

Signature with Seal: [Signature]

Name: Executive Engineer
Designation: P. H. DIVISION GAYA

hll
22.02.25


To
Gyan Taru Public
School Educational
Trust Mastalipur Manpur
(Name & Address of the Institution) Gaya

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
 Public Health Engineering Department
 P.H. DIVISION, GAYA

Physico-Chemical & Bacteriological Examination Report of Drinking Water Sample of Gaya														
Sample Collected By :	Ranjeet kumar											Sample Received on : 23.01.2025		
SL No	Location of Source	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Bacteria (+, -)	Remarks	
1	Gyan Taru Public School Mastalipur, Manpur Gaya	0.49	480	312	232	51.30	25.27	59.98	256	0.38	7.34	-ve		
Reporting Date :	27.01.2025	Desirable Limit	1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	-ve	
		Permissible Limit in absence of alternate source IS:10500:2012	5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	-ve	

*NR-No Relaxation.

जल नमूना का संग्रह दिनांक 23-01-25
 Ranjeet kumar के द्वारा किया गया है ।


 27-01-25
 Chemist

P.H. Division, Gaya